

# Energy Performance Certificate

## Address of dwelling and other details



2/2  
6 TANNADICE STREET  
DUNDEE  
DD3 7PQ

Dwelling type:  
Name of approved organisation::  
Membership number:  
Date of certificate:  
Reference number:  
Type of assessment:  
Total floor area:  
Main type of heating and fuel:

Mid-floor flat  
Stroma Certification  
STRO003123  
25 February 2010  
2958-1006-4202-2870-5900  
RdSAP, existing dwelling  
35 m<sup>2</sup>  
Room heaters, electric

## This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2005 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO<sub>2</sub>) emissions. CO<sub>2</sub> is a greenhouse gas that contributes to climate change.

| Energy Efficiency Rating                    |    | Current   | Potential | Environmental Impact (CO <sub>2</sub> ) Rating                  |    | Current   | Potential |
|---|----|---|-----------|---|----|---|-----------|
| Very energy efficient - lower running costs |    |   |           | Very environmentally friendly - lower CO <sub>2</sub> emissions |    |   |           |
| (92 plus) A                                 |    |   |           | (92 plus) A   |    |   |           |
| (81-91) B                                   |    |   |           | (81-91) B   |    |   |           |
| (69-80) C                                   |    |   |           | (69-80) C   |    |   |           |
| (55-68) D                                   |    |   |           | (55-68) D   | 61 | 63  |           |
| (39-54) E                                   | 44 | 46  |           | (39-54) E   |    |   |           |
| (21-38) F                                   |    |   |           | (21-38) F   |    |   |           |
| (1-20) G                                    |    |   |           | (1-20) G  |    |   |           |
| Not energy efficient - higher running costs |    |   |           | Not environmentally friendly - higher CO <sub>2</sub> emissions |    |   |           |
| <b>Scotland</b>                             |    | EU Directive 2002/91/EC  |           | <b>Scotland</b>   |    | EU Directive 2002/91/EC  |           |

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.

Approximate current energy use per square metre of floor area: 438 kWh/m<sup>2</sup> per year

Approximate current CO<sub>2</sub> emissions: 66 kg/m<sup>2</sup> per year

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating the less impact it has on the environment.

## Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above.

- 1 Add additional 80 mm jacket to hot water cylinder
- 2 Low energy lighting for all fixed outlets

*A full energy report is appended to this certificate*



Remember to look for the energy saving recommended logo when buying energy-efficient products. It's a quick and easy way to identify the most energy-efficient products on the market.

This EPC and recommendations report may be given to the Energy Saving Trust to provide you with information on improving your dwelling's energy performance.

**N.B. THIS CERTIFICATE MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED VERSION**

## Energy Report



The Energy Performance Certificate and Energy Report for this dwelling were produced following an energy assessment undertaken by a member of Stroma Certification. This is an organisation which has been approved by the Scottish Ministers. The certificate has been produced under the Building (Scotland) Amendment Regulations 2006 and a copy of the certificate and this energy report have been lodged on a national register.

Assessor's name: Gordon Murray  
Company name/trading name: Scottish Energy Certificates  
Address: No 5 Ruthvenmill View, Perth, PH1 3JL  
Phone number: 01738580755  
Fax number: 0000  
E-mail address: gmurray@talktalkbusiness.net  
Related party disclosure: No related party

### Estimated energy use, carbon dioxide (CO<sub>2</sub>) emissions and fuel costs of this home

|                          | Current                         | Potential                       |
|--------------------------|---------------------------------|---------------------------------|
| Energy use               | 438 kWh/m <sup>2</sup> per year | 421 kWh/m <sup>2</sup> per year |
| Carbon dioxide emissions | 2.3 tonnes per year             | 2.2 tonnes per year             |
| Lighting                 | £32 per year                    | £18 per year                    |
| Heating                  | £365 per year                   | £380 per year                   |
| Hot water                | £233 per year                   | £208 per year                   |

### About the building's performance ratings

The ratings on the certificate provide a measure of the building's overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used.

Not all buildings are used in the same way, so energy ratings use 'standard occupancy' assumptions which may be different from the specific way you use your home.

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings on the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

### About the impact of the buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple everyday measures that will save money, improve comfort and reduce the impact on the environment. Some examples are given at the end of this report.

## Summary of this home's energy performance related features

The table below gives an assessment of the key individual elements that have an impact on this home's energy and environmental performance. Each element is assessed by the national calculation methodology against the following scale: Very poor / Poor / Average / Good / Very good. The assessment does not take into consideration the physical condition of any element. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology based on age and type of construction.

| Element               | Description                                  | Current Performance |               |
|-----------------------|--|---------------------|---------------|
|                       |  | Energy efficiency   | Environmental |
| Walls                 | Sandstone, as built, no insulation (assumed) | Poor                | Poor          |
| Roof                  | (another dwelling above)                     | -                   | -             |
| Floor                 | (other premises below)                       | -                   | -             |
| Windows               | Single glazed                                | Very poor           | Very poor     |
| Main heating          | Room heaters, electric                       | Very poor           | Poor          |
| Main heating controls | No thermostatic control of room temperature  | Poor                | Poor          |
| Secondary Heating     | None   | -                   | -             |
| Hot water             | Electric immersion, standard tariff          | Very poor           | Poor          |
| Lighting              | Low energy lighting in 20% of fixed outlets  | Poor                | Poor          |

**Current energy efficiency rating**

**E 44**

**Current environmental impact (CO<sub>2</sub>) rating**

**D 61**

## Low and zero carbon energy sources

### Recommended measures to improve this home's energy performance

The measures below are cost effective. The performance ratings after improvement listed below are cumulative, that is they assume the improvements have been installed in the order that they appear in the table. However you should check the conditions in any covenants, warranties or sale contracts, and whether any legal permissions are required such as a building warrant, planning consent or listed building restrictions.

| Lower cost measures (up to £500)                           | Typical savings per year | Performance ratings after improvement |                      |
|--|--------------------------|---------------------------------------|----------------------|
|  |                          | Energy efficiency                     | Environmental impact |
| 1 Add additional 80 mm jacket to hot water cylinder        | £17                      | E 45                                  | D 62                 |
| 2 Low energy lighting for all fixed outlets                | £7                       | E 46                                  | D 63                 |
| Sub-total  | £24                      |                                       |                      |
| <b>Higher cost measures (Over £500)</b>                    |                          |                                       |                      |
| 3 Fan assisted storage heaters and dual immersion cylinder | £275                     | C 73                                  | D 61                 |
| Total  | £299                     |                                       |                      |

**Potential energy efficiency rating**

**C 73**

**Potential environmental impact (CO<sub>2</sub>) rating**

**D 61**

### Further measures to achieve even higher standards

The measures listed below should be considered if aiming for the highest possible standards for this home. Some of these measures may be cost-effective when other building work is being carried out such as an alteration, extension or repair. Also they may become cost-effective in the future depending on changes in technology costs and fuel prices. However you should check the conditions in any covenants, warranties or sale contracts, and whether any legal permissions are required such as a building warrant, planning consent or listed building restrictions.

|   |     |      |      |
|---|-----|------|------|
| 4 Replace single glazed windows with low-E double glazing | £57 | C 78 | D 68 |
|---|-----|------|------|

**Enhanced energy efficiency rating**

**C 78**

**Enhanced environmental impact (CO<sub>2</sub>) rating**

**D 68**

Improvements to the energy efficiency and environmental impact ratings will usually be in step with each other. However, they can sometimes diverge because reduced energy costs are not always accompanied by reduced carbon dioxide (CO<sub>2</sub>) emissions.

## About the cost effective measures to improve this home's performance ratings

If you are a tenant, before undertaking any work you should check the terms of your lease and obtain approval from your landlord if the lease either requires it, or makes no express provision for such work.

### Lower cost measures (typically up to £500 each)

These measures are relatively inexpensive to install and are worth tackling first. Some of them may be installed as DIY projects. DIY is not always straightforward, and sometimes there are health and safety risks, so take advice before carrying out DIY improvements.

#### 1 Hot water cylinder insulation

Increasing the thickness of existing insulation by adding an 80 mm cylinder jacket around the hot water cylinder will help maintain the water at the required temperature; this will reduce the amount of energy used and lower fuel bills. The jacket should be fitted over the top of the existing foam insulation and over any thermostat clamped to the cylinder. Hot water pipes from the hot water cylinder should also be insulated, using pre-formed pipe insulation of up to 50 mm thickness, or to suit the space available, for as far as they can be accessed to reduce losses in summer. All these materials can be purchased from DIY stores and installed by a competent DIY enthusiast.

#### 2 Low energy lighting

Replacement of traditional light bulbs with energy saving recommended ones will reduce lighting costs over the lifetime of the bulb, and they last up to 12 times longer than ordinary light bulbs. Also consider selecting low energy light fittings when redecorating; contact the Lighting Association for your nearest stockist of Domestic Energy Efficient Lighting Scheme fittings.

### Higher cost measures (typically over £500 each)

#### 3 Fan assisted storage heaters

Modern storage heaters are much less expensive to run than the direct acting, on-peak heating system in the property. A dual-rate electricity supply is required to provide the off-peak electricity that these heaters use; this is easily obtained by contacting the energy supplier. Ask for a quotation for fan-assisted heaters with automatic charge control. A dual-immersion cylinder, which can be installed at the same time, will provide cheaper hot water than the system currently installed. Installations should be in accordance with the national wiring standards. Building regulations may apply to this work, so it is best to obtain advice from your local authority building standards department and from a qualified electrical heating engineer. Ask the heating engineer to explain the options, which might also include switching to other forms of electric heating.

## About the further measures to achieve even higher standards

Further measures that could deliver even higher standards for this home. You should check the conditions in any covenants, planning conditions, warranties or sale contracts before undertaking any of these measures. If

you are a tenant, before undertaking any work you should check the terms of your lease and obtain approval from your landlord if the lease either requires it, or makes no express provision for such work.

#### 4 Double glazing

Double glazing is the term given to a system where two panes of glass are made up into a sealed unit. Replacing existing single-glazed windows with double glazing will improve comfort in the home by reducing draughts and cold spots near windows. Double-glazed windows may also reduce noise, improve security and combat problems with condensation. Building standards may apply to this work, so it is best to obtain advice from your local authority building standards department.

## What can I do today?

Actions that will save money and reduce the impact of your home on the environment include:

- Ensure that you understand the dwelling and how its energy systems are intended to work so as to obtain the maximum benefit in terms of reducing energy use and CO2 emissions.
- Check that your heating system thermostat is not set too high (in a home, 21°C in the living room is suggested) and use the timer to ensure you only heat the building when necessary.
- Make sure your hot water is not too hot - a cylinder thermostat need not normally be higher than 60°C.
- Turn off lights when not needed and do not leave appliances on standby. Remember not to leave chargers (e.g. for mobile phones) turned on when you are not using them.
- Close your curtains at night to reduce heat escaping through the windows.
- If you're not filling up the washing machine, tumble dryer or dishwasher, use the half-load or economy programme.

For advice on how to take action and to find out about offers available to help make your home more energy efficient, call 0800 512 012 or visit [www.energysavingtrust.org.uk](http://www.energysavingtrust.org.uk).